

THANK YOU REV2024 SPONSORS!





PERFORMANCE CONTRACTING PANEL DISCUSSION

REV 2024 Conference

BIOMASS BOILER SYSTEMS

Mark Froling
Froling Energy

Mechanical Contractor

Focused on the Installation of High Efficiency, Low Emissions Commercial Biomass Boiler Systems



Dry Wood Fuel Producer & Delivery Service

Of PDCs—Screened Dried Wood Chips
25% Moisture Content, Delivered by Blower Truck

For 15 years we have focused on Installing Wood Pellet & Chip Boiler Systems in Schools and other Commercial Buildings

Bellows Falls Middle School



Mill River Union HS, Colchester



Green Street School, Brattleboro



Sharon Elementary School



3 Wood Fuels for Automated Heating Available in Vermont, NH, Maine and Massachusetts

Wood Pellets



Manufactured at 12 locations
in New England

Screened Dried Wood Chips



Froling Energy makes them. Others will in
future.

Green Wood Chips



Available from many local logging
companies and regional distributors



Current Annual Heating Fuel Costs
Compare by Energy Unit (MMBTU)

HEATING OIL

\$28/MMBTU at \$3.33/Gal

PELLETS

\$22/MMBTU at \$306/Ton

DRIED CHIPS

\$16/MMBTU at 165/ton

GREEN CHIPS

\$12/MMBTU at \$75/Ton

Wood Pellets

7% moisture content

Precisely controlled small size Flows like water.

Bole Wood—minimal bark

Most compact BTU storage

Assured Quality

Delivery by Blower Truck



Fuel Storage Options



Screened Dried Wood Chips

25% moisture content Screened: Nothing bigger than a matchbook


Bole Wood—minimal bark

Assured Quality

Delivery by Blower Truck



Fuel Storage Options



Green Wood Chips

35% to 50% moisture content

Chip size and % bark vary. Rocks/debris possible

Quality is determined by price & Vendor (Buyer Beware!)

**Delivery by Live Floor
Truck into a Pit**



Fuel Storage Options



Commercial Project: Motivations

Sustainability Goals

Reduce Heating Fuel Costs

Replace Aging Boilers & Leaky Oil Tanks

Desire to Support Region's Forest
Economy

Improve Heat Distribution/Comfort

Central control system: None/Outdated

Additions & Renovations being Planned

Rural Choices: Oil, Propane or Wood?

Rutland Intermediate School



Dummerston School



Commercial Project: Common Traits

Big Buildings—30 to 100+ years old

Architecturally difficult for deep energy retrofits

Big Heating Fuel Users

Central Heat Distribution Systems

Well ventilated—or need to be!

Redundant Boilers

Require High Temperature Heat (160-190 F)

Steam Heat!

Academy School, Brattleboro



Bellows Falls Middle School



Commercial Project: Challenges

Small Boiler Room—no space!

Can a new boiler building be justified?

Where might it be located?

Tight Access into Boiler Room for Big Boilers

No room for a Buffer Tank

Multiple chimney flues required

Can Silo be near enough to Boiler Room?

Multiple Boiler Rooms heat different areas

Can they be tied together?

Dummerston School



Stafford Tech in Rutland

Commercial Project: Funding

Two Major Methods:

Local Bond Issue

- Approved by public vote

Energy Performance Contractor

- Approved by public vote
- But with a much more attractive financial picture—Revenue Neutral

Mill River Union High School



Stafford Tech in Rutland

Plymouth Regional High School

Plymouth, NH

Silo Capacity: 42 tons of PDCs



Boiler Output: 2.45 Million BTU/Hr

John Stark High School Weare, NH

- Averaged 38,000 Gal/Yr and \$133,000/Yr
- After Conversion with Froling & EEI
- Now Averaging 250 Ton/@ 165 \$41,250



**Dry Chip Boiler Output:
1.7 Million BTU/Hr**




**Silo Capacity:
42 tons of PDCs = 3,900 Gal Oil**



Otter Valley Union High School

Brandon, VT



Prior Fuel Use: 60,000gal/yr
\$210,000yr
Now, Pellet and Fuel Costs:
\$140,000yr



2 Existing Boiler Rooms with multiple Oil-fired boilers.
Pellet Boiler system was put into a new 3rd boiler room

Otter Valley Union High School

Brandon, VT



Viessmann Pyrot 540 KW boiler
has 1,843,000 BTU/hr peak output
Features: Flue gas recirculation, Pneumatic tube cleaning



3 – 300 Gallon Buffer Tanks in Parallel

St. Johnsbury School St. Johnsbury, VT



New brick boiler building matches school




Schmid UTSK 500 KW Boiler: 1.6 Million BTU/Hr



Silo holds 42 tons of Dried Chips
Equals 3,930 gal #2 Oil

Green Street School Brattleboro, VT

End of Life Oil Boiler
Prior Fuel Use:
12,500 Gallons of Oil



Steam Heat
Original Coal Boiler was still in place
but disconnected



1924 Building
30,700 Sq Ft Area



Green Street School Brattleboro, VT



New Fuel Use:

83 tons of Dried Wood Chips
4,000 Gallons of LP
A 15% reduction in fuel use



Froling T4-150 Dried Chip/Pellet
Boiler
512,000 BTU/Hr
(Right: Gas Boiler & Buffer Tanks)



Interior Silo holds
12 tons of Dried wood chips



Mill River Union High School North Clarendon, VT



Average Prior Heating Fuel Use:
47,000 Gallons of Oil per year at \$164,000

New Annual Fuel Use:
350 Tons of dried chips + 5,000G at \$75,275



Difficult access into boiler room

Mill River Union High School

North Clarendon, VT



New HB Smith LP-Fired Steam Boiler
Output: 2.4 Million BTU/Hr

New Schmid UTSK Dried Chip Steam Boiler
Output: 1.87 Million BTU/Hr



Dried Chip feed auger to boiler

Mill River Union High School North Clarendon, VT



Sweeper arm at bottom of silo



Augers feed dried chips from silo into the boiler



BUILDING AUTOMATION SYSTEMS

Chris Clorite
Control Technologies Inc






CHRIS CLORITE SALES ENGINEER

25 years HVAC experience from a service technician to working at an Engineering firm as a mechanical design engineer.

Most of my career has been at Control Technologies Inc. where I have been a DDC Engineer, Project Manager, and most recently Sales Associate




Building Automation Controls

What do controls people really do?


Turn things on/off
Move things back/forth

Based on information collected
throughout the building


Simplifies operation of complex
systems



The control system provides real time information



Graphical User Interface



Energy Monitoring



Remote Access

The image shows an 'Alarms' notification screen. The title is 'Alarms' and the subtitle is 'New York City School- PS 2262'. The screen displays a list of alarm events. A green box highlights the title 'Event (alarm) notification'. The table below shows the following data:

Time	Event Name	Status	Priority	Location	Details
28-Nov-18 3:47:30 PM EST	RTU_02_ReturnFanAlarmStatus	Normal	0	Room_Q262	RTU_02_ReturnFanAlarmStatus
30-Nov-18 1:30:28 PM EST	Kitchen-COAlarm	Normal	0	Room_Q262	Kitchen-COAlarm Back to Normal
30-Nov-18 7:48:38 AM EST	EP03-SupplyFanAlarm	OffNormal	0	Room_Q262	EP03-SupplyFanAlarm Out of Spec
30-Nov-18 7:48:24 AM EST	EP02-SupplyFanAlarm	OffNormal	0	Room_Q262	EP02-SupplyFanAlarm Out of Spec
19-Nov-18 9:11:43 AM EST	RTU_04-SupplyFanAlarm	OffNormal	0	Room_Q262	RTU_04-SupplyFanAlarm Out of Spec
09-Nov-18 8:00:59 AM EST	RTU_03-SupplyFanAlarm	OffNormal	0	Room_Q262	RTU_03-SupplyFanAlarm Out of Spec
09-Nov-18 6:01:05 PM EST	RTU_03-ExhaustFanAlarm	OffNormal	0	Room_Q262	RTU_03-ExhaustFanAlarm Out of Spec
07-Nov-18 8:21:46 AM EST	RTU_02-ExhaustFanAlarm	OffNormal	0	Room_Q262	RTU_02-ExhaustFanAlarm Out of Spec
07-Nov-18 8:21:45 AM EST	RTU_01-SupplyFanAlarm	OffNormal	0	Room_Q262	RTU_01-SupplyFanAlarm Out of Spec

Event (alarm) notification



Archives and Trends



FTR_15
69.2 °F

HC_04_00
66.6 °F

HC_03_00
69.8 °F

HC_02_01
70.3 °F

RP_01
68.6 °F

RP_02
66.8 °F

HC_03_02
71.2 °F

HC_02_02
69.4 °F

HC_02_00
70.3 °F

HC_05_00
68.1 °F

BIOMASS



HWS Setpoints

HotWaterSysEnabled
YES
OutsideAirHWSysEnabled: 60 °F
HWSupplyTempSp
110 °F
OAFForMaxSp
20 °F
HWSupplyTempSpMax
180 °F
OAFForMinSp
60 °F
HWSupplyTempSpMin
120 °F

Biomass Info

WoodChipBoilerEnable
Disabled
WoodChipBoilerEnableSp
120 °F
Alarms
LowHWSupplyTemperature
Normal
LpBoilerEnabled3Times
Normal

DP01StartStop
Start
DP01Status
Running
DP01AlarmStatus

Reset

Combustion Damper



CombustionDamper
Open
CombustionDamperAlarm
Normal

Reset

EF07B



RoomTemperature
83 °F
RoomTempSpCooling
85 °F
EF07BStartStop
Stop
EF07BStatus
Stopped
ExhaustFan07BAlarmStatu

Reset

Boiler02SupplyTemp
150 °F

HWSupplyTemperature
147 °F

InjectionPumpStartStop
Stop
InjectionPumpStatus
Stopped
InjectionPumpSpeed
0 %
InjectionPumpAlarmStatu
Normal

Reset

DP02StartStop
Start
DP02Status
Running
DP02AlarmStatus

Reset

ElemHWSupply
132 °F

Elem. Loop

HX_TempLeaving
138 °F



LPGasBoilerEnable
Disabled
Boiler02SetpointSigna
44 %
Boiler02Alarm



Boiler01Alarm
Normal
Y T D EnergyTotal S
974572 kBTU

Schmid Boiler :

GymHWSupplyTemp
145 °F

Gym Loop

GymHWRReturnTemp
148 °F


Override Lp Boiler "ON" if Biomass is turned off and a boiler is needed

90.5 %RH
 18.7 BTU/lb
 Unit Operating Mode Stopped
 SupplyDuctSmoke Normal
 Unit Alarm Status Normal

ReturnHumidity 44 %RH
 ReturnHumiditySp 60 %RH
 HotGasReheatValve 0 %



EconOaEnthalpyEnableSp 26 btu/lb
 EconOaRaEnthalpyDiffSp 1 btu/lb
 OutsideDamper 0 %
 OutsideDamperMinSp 25 %
 DXCapacityFeedback 0
 DXCapacity 0 %
 SupplyFanStartStop Disable
 SupplyFanStatus Stopped
 SupplyFanAlarmStatus Normal
 SupplyFanSpeed 0 %
 SupplyFanMinSpeedSp 60 %
 SupplyFanMaxSpeedSp 85 %



ExhaustFanStartStop Disable
 ExhaustFanStatus Running
 ExhaustFanAlarmStatus Normal
 ExhaustFanSpeed 0 %
 ExhaustFanSpeedOffset 10 %
 EnergyWheelStartStop Disable
 EnergyWheelSpeed 0 %
 ReturnTemperature 68 °F
 ReturnHumidity 44 %RH
 RaEnthalpy 23.5 BTU/lb
 ReturnCarbonDioxide 357 ppm
 ReturnCarbonDioxideSp 1000 ppm

HeatingCoilValve 0 %

Supply Temperature Reset Control

	Min Demand	Max Demand	Current Room Demand
Heating	72 °F	90 °F	0
Cooling	68 °F	55 °F	0

Current Supply Temp 72 °F
 Calc. Supply Temp Setpoint 70 °F


NOTE: "Room Demand" is generated by how far Room Temperature is above or below setpoint

Space Temperature Controls

RoomTemperature 68.5 °F
 RoomTempSp 68 °F

Heating	Cooling
Active SP 55 °F	Active SP 85 °F
Offset 0 °F	Offset 2 °F
Unocc SP 55 °F	Unocc SP 85 °F

Room Temperature Chart



Stage_Vest	131 Social Studies	65.5 °F	55 °F	70 °F	55 °F	0 %	Unoccupied	Unoccupied	NO
Stage_Storage	134 Social Studies	63.0 °F	55 °F	70 °F	55 °F	0 %	Unoccupied	Unoccupied	NO

Rm_A108	132 Social Studies	67.6 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A109	134 Social Studies	69.2 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A110	129 Social Studies	69.0 °F	65 °F	70 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A111	conference room	68.9 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A112	134 Social Studies	69.3 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A113	Councillors office	70.1 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A114	132 Social Studies	71.6 °F	65 °F	72 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A115	134 Social Studies	68.7 °F	65 °F	72 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A116	129 Social Studies	69.4 °F	65 °F	70 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_A117	131 Social Studies	68.7 °F	72 °F	70 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
AdminNHall	131 Social Studies	66.7 °F	65 °F	75 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
AdminSHall	131 Social Studies	66.8 °F	65 °F	70 °F	65 °F	0 %	Unoccupied	Unoccupied	YES

Rm_C110	Greenhouse	64.5 °F	55 °F	70 °F	55 °F	0 %	Unoccupied	Unoccupied	NO
Rm_C201	132 Social Studies	66.8 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C202	132 Social Studies	68.4 °F	68 °F	72 °F	68 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C203	134 Social Studies	70.2 °F	65 °F	70 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C204	134 Social Studies	67.7 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C205	134 Social Studies	67.2 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C206	132 Social Studies	67.6 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C207	132 Social Studies	67.2 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C208	134 Social Studies	67.3 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C210	132 Social Studies	68.0 °F	68 °F	68 °F	68 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C213	134 Social Studies	67.7 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C214	132 Social Studies	67.9 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C215	134 Social Studies	69.1 °F	68 °F	70 °F	68 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C218	132 Social Studies	69.7 °F	69 °F	72 °F	69 °F	100 %	Unoccupied	Unoccupied	YES
Rm_C219	134 Social Studies	67.8 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
Rm_C220	132 Social Studies	67.6 °F	65 °F	68 °F	65 °F	0 %	Unoccupied	Unoccupied	YES
C_Wing_Stairs	129 Social Studies	67.2 °F	65 °F	70 °F	65 °F	0 %	Unoccupied	Unoccupied	NO
C_Wing_Entr	134 Social Studies	65.2 °F	65 °F	68 °F	65 °F	100 %	Unoccupied	Unoccupied	NO



Control Optimization

Demand Control Ventilation

Resets (OA and Building)

Schedule Zones

Load Shedding

ASHRAE Guideline 36 Trim and Respond

PERFORMANCE CONTRACTING & WOOD HEAT CASE STUDIES

Eric Lafayette

EEI



ERIC LAFAYETTE PROJECT DEVELOPER

- Project Developer
- Burlington, VT – BHS Grad of 06’
- Roger Williams University in Rhode Island majoring in Construction Management
- Live in So. Burlington w/ wife & two girls
- VT School Construction Aid Task Force



Who is EEI?

- ESCO (Energy Service Company) that provides “turn-key” energy services typically through performance contracting
- Based in Merrimack, NH; office in Williston, VT
- We help schools, universities, hospitals, and municipalities meet their energy goals – Analysis to Completion
- We focus on efficiency & sustainability trying to utilize renewable energies



Currently working at Springfield School District, Hannaford Career Center, Missisquoi Salley Supervisory Union, Burlington City & Schools, Barre School District, Two River SU, White River SU, & Orleans

Why am I Here – Performance Contracting?

- Performance Contracting and its ability to address key infrastructure problems in the state affordably
- Delivery Methods for Schools & Municipalities
- Currently Plan & Spec. & Construction Manager where an Architect leads the project planning
- Owner hires Architect & Engineering firm and they start a long review of capital needs and potential options



Why Energy Performance Contracting?

- Delivery Method Focused on Results
- We Help Finance - Reduced energy costs help to finance the project
 - *Help customers attain grants & rebates – State & Federal*
 - *Provide Investment Grade Audits to finance lower cost lease payments for energy efficiency*
 - *Provide lending opportunities to our clients through various means*
- Numerous Options w/ Upfront Costs
 - *We do not want to think “What if we had tried this”*
- Maximize Rebates & Grants
 - *Significant rebates from Efficiency Vermont*
 - *Utilize the Inflation Reduction Act (IRA) or other rebate*
- No Risk or Cost to Schools Upfront – if we can’t come up w/ energy savings projects that the school accepts to, there is no charge for our services
- Continuous Commissioning
 - *On going analytics have allowed for increases in savings over a period of time – continuously monitoring the system*

Our Process



**LONG TERM RELATIONSHIPS
PARTNERS IN ENERGY**



Identify Options

Identify building inefficiencies and provide “a-la-cart” energy cost measures that reduce building operating expenses (utility & operational)

Review

Review all options with the owner and align measures with the goals and objective of the owner – Steam Heating, Geothermal, Solar, CO2 Reduction, Renewable Energies

Review “magnitude of cost” for each measure and present potential energy savings & grant opportunities for each measure.

Design

Owner selects measures for development – EEI then engages the design team to put measures to paper. We then develop the final energy savings & guaranteed savings

Procurement

EEI reviews design, schedule, and updated pricing with the owner based on engineers design

EEI procures work by creating bid packages and putting the project out to bid

Site Management

EEI provides on site management constructs project with a team of subcontractors

Commissioning & Guaranteed Savings

EEI commissions the building and provides ongoing data analytics & measurement & verification

Options & analysis we provide

- What is the fuel source of the future?
- Oil, LP, Biomass, Geothermal, electric heat pump
- 2. Does the campus keep Steam or Convert to hot water?
- Maintaining a Steam system means standard efficient boilers and a commitment to fossil fuel or biomass
- Key infrastructure still needs upgrade but could reuse some boilers and building mechanical rooms
- Do they stay on oil or propane – or move away from fossil fuels
- How far do we take the energy upgrades, and where does it go?
- Should we change the lights to LED?
- What additional code or capital needs do we need.
- Phased Approach



Case Study - Bethel Middle School

Existing Situation

- Pneumatic Controls that were past end of life
- The steam traps had failed around the building and the owner group had a retiring maintenance staff
- Fluorescent Lighting
- Oil as primary heat source burning around 45,000 /gallons year





Biomass Wood Chip Boiler

- ✓ Cheaper Fuel Source
- ✓ Reduction of CO₂
- ✓ 80% of cost stays within a 60-mile radius
- ✓ 40-year infrastructure investment
- ✓ Renewable energy source



Challenges

- Decisions - Dry Chip vs. Pellet
- Space issues & access
- ACT 250 Permitting
- Because the site had an active ACT 250 permit, this triggered a decision
- Multiple funding sources with strict guidelines for use & timelines
- Oil as primary heat source burning around 45,000 /gallons year

ECM Matrix - Bethel Campus

Measure	Description	Cost	Savings	Grants	Rebate
ECM 1	Remove Existing Underground Fuel Oil Tank	\$35,000			
ECM 2	Install Underground LP Tanks & Pipe to the Building (4 Underground - 1,000 Gallon Tanks)	\$50,000			
ECM 3	Add Wood Pellet Boiler w/ LP Backup	\$675,000	\$48,000		
ECM 4	Convert Steam to Hydronic	\$425,000		\$250,000	\$24,000
ECM 5	DDC Control System	\$245,000	\$4,200		
ECM 6	LED Lighting upgrade throughout (fixture replacement)	\$240,000	\$12,000		\$65,000
ECM 7	Abestos Abatement (allowance)	\$50,000			
	Total	\$1,720,000	\$64,200	\$250,000	\$89,000
	Less Grants & Rebates	\$1,381,000			
	WRVSU ESSER Contribution	\$310,000			
	Bethel/Royalton Responsibility	\$1,071,000			
	15 Year Lease on LED Lighting & Pellet Boiler	\$920,000			
	WRVSD - Contribution	\$151,000			






Results

- In 2024 we used 9,000 gallons of Propane & 145 tons of wood chip
- Total Fuel Savings \$58,000 / Year
- Completed Wood Chip January 2024
- Utilized Propane for first part of heating season
- Electrical lighting savings slightly below projected due to new split system, heat pump hot water, heater
- All new Heating System – no more service calls, DDC web based controls, & continuous commissioning looking for added savings this year

Case Study - Addison Northwest SU

In 2017, after a competitive selection process, EEI was selected to complete an energy audit

- Driver of the project was the failed steam and boiler system at VUHS.
- The project was completed in late 2018 and include
- Condensing gas boilers at VUHS and VES
- Solar Panels VUHS
- Several new ventilation units at all 4 Schools
- Fire Safety improvements ant VES
- LED Lighting at all Schools





THANK YOU

Eric Lafayette
Project Developer / Manager
elafayette@eeiservices.com

THANK YOU REV2024 SPONSORS!

